


# PRODUCT SAFETY RECALL

**RCD branded PDL POWERGUARD Vertical Switched Socket** – PDL Cat: 691RCD30WH; and

**RCD branded PDL POWERGUARD Rewireable Cord-set** – PDL Cat: 955RW; 953/15; 954;  
955; 955/10; NT955BULK; 956

The Residual Current Devices may not provide any protection against electric shock or fire as intended, in the event of an electrical fault in connected electrical equipment.

Batch code **0507** (week 05 of 2007) sold nationally between March 2007 and January 2008. Please refer to the below images to locate the position of the batch code:



**SAFETY ISSUE:** FAILURE OF THE RCD TO OPERATE AS INTENDED MAY RESULT IN SERIOUS HARM / ELECTROCUTION AND / OR FIRE.

**WHAT TO DO:** If you identify the **0507** batch code you should stop using the products and immediately seek advice from the number below.

The products from the **0507** batch code will be replaced free of charge.

Contact Schneider Electric NZ Ltd by:

**Free Phone: 0800 735 326 between 8am and 8pm, or**

**Free Fax: 0800 739 939, or e-mail: [rcdsafety@nz.schneider-electric.com](mailto:rcdsafety@nz.schneider-electric.com)**

Instructions will be provided on how each product will be replaced upon contacting us.

**NO OTHER PDL ITEMS ARE AFFECTED**