



This safe work instrument is administered by WorkSafe New Zealand. For more information please see:

Website: <http://www.worksafe.govt.nz>

Contact phone: 0800 030 040

Contact address: PO Box 165 Wellington 6140 New Zealand

Health and Safety at Work (Hazardous Substances— Thermoplastic Stationary Tanks) Safe Work Instrument 2017

This safe work instrument is approved under section 227 of the Health and Safety at Work Act 2015 by the Minister for Workplace Relations and Safety, being satisfied that—

- (a) appropriate consultation has been carried out under section 227(3) of that Act; and
- (b) in accordance with regulation 17.105(2) of the Health and Safety at Work (Hazardous Substances) Regulations 2017, for the purposes of clauses 11 and 12, compliance with the provisions of the Regulations that apply to stationary tanks will not appropriately control risk associated with certain stationary tanks.

Contents

	Page
1 Title	2
2 Commencement	2
3 Overview	2
4 Interpretation	2
5 Application	3
6 Design must be in accordance with specified standards	3
7 Requirements relating to service life and materials	4
8 Welding of tank during construction	4
9 Testing to be conducted by PCBU	4
10 Marking	5
11 Installation	5
12 Operation	5

13 Maximum period of compliance certificate 6

Safe Work Instrument

1 Title

This is the Health and Safety at Work (Hazardous Substances—Thermoplastic Stationary Tanks) Safe Work Instrument 2017.

2 Commencement

This safe work instrument comes into force on 1 December 2017.

3 Overview

In this safe work instrument—

- (a) clauses 6 to 9 specify requirements relating to design and construction of a tank for the purposes of regulation 17.6(1)(k) of the Regulations:
- (b) clause 10 specifies requirements for the marking of a tank for the purposes of regulation 17.76(1)(b)(ii) of the Regulations:
- (c) clause 11 sets out additional requirements that apply to the installation of a tank and states which PCBUs are required to comply with those additional requirements for the purposes of regulation 17.105 of the Regulations:
- (d) clause 12 sets out additional requirements that apply to the operation of a tank and states which PCBUs are required to comply with those additional requirements for the purposes of regulation 17.105 of the Regulations:
- (e) clause 13 specifies the maximum period of validity for which a compliance certificate for a tank may be issued for the purposes of regulation 17.92(1)(a)(i)(E) of the Regulations.

4 Interpretation

- (1) In this safe work instrument, unless the context otherwise requires,—

Act means the Health and Safety at Work Act 2015

AS/NZS 3845 means the Australian/New Zealand standard AS/NZS 3845:1999 Road safety barrier systems

BS EN 1778 means the British/European standard BS EN 1778:2000 Characteristic values for welded thermoplastics constructions — Determination of allowable stresses and moduli for design of thermoplastics equipment

BS EN 12573-1 means the British/European standard BS EN 12573-1:2000 Welded static non-pressurized thermoplastic tanks – Part 1: General principles

BS EN 12573-2 means the British/European standard BS EN 12573-2:2000 Welded static non-pressurized thermoplastic tanks – Part 2: Calculation of vertical cylindrical tanks

BS EN 12573-3 means the British/European standard BS EN 12573-3:2000 Welded static non-pressurized thermoplastic tanks – Part 3: Design and calculation for single skin rectangular tanks

BS EN 12573-4 means the British/European standard BS EN 12573-4:2000 Welded static non-pressurized thermoplastic tanks – Part 4: Design and calculation of flanged joints

DVS 2203 means the Deutscher Verband für Schweißen und Verwandte Verfahren (German Association for Welding and Associated Procedures) standard DVS 2203 Testing of welded joints between panels and pipes made of thermoplastics

Regulations means the Health and Safety at Work (Hazardous Substances) Regulations 2017

tank means an above ground stationary tank to which this safe work instrument applies

- (2) Any term or expression that is defined in the Act or the Regulations and used, but not defined, in this safe work instrument has the same meaning as in the Act or the Regulations.

5 Application

This safe work instrument applies to a vertical, cylindrical above-ground stationary tank that—

- (a) subject to clause 12(1), is used for the storage of a hazardous substance of class 5, 6, or 8 substance; and
- (b) has a capacity of not more than 60 000 L; and
- (c) is constructed from polypropylene or high-density polyethylene.

6 Design must be in accordance with specified standards

- (1) A relevant PCBU must ensure that a tank is designed and constructed in accordance with—
- (a) the provisions of BS EN 1778 relating to—
 - (i) either—
 - (A) the characteristic values for welded thermoplastic construction, including the determination of long-term allowable stresses, long-term elastic modulus values and the de-rating factors to be applied when materials are exposed to different chemicals; or
 - (B) in the case of a tank that is to contain a substance other than a substance referred to in BS EN 1778 or is to be constructed of a material for which the supplier has provided accurate data, the methodology that applies when determining allowable stresses, as if the substance or the data were referred to in BS EN 1778; and
 - (ii) the exercising of judgement by engineers in making ‘fit for purpose’ decisions in relation to unusual plastic constructions; and

- (b) the provisions of BS EN 12573-1 relating to the determination of allowable stresses including the calculation of cyclical loadings and combination loadings for tank designs detailed in BS EN 12573-2; and
 - (c) the provisions of BS EN 12573-2 relating to the design and calculation of welded, static, vertical, non-pressurised, cylindrical, flat-bottomed thermoplastic tanks, where applicable; and
 - (d) the provisions of BS EN 12573-3 relating to the construction of nozzles welded into thermoplastic vessels; and
 - (e) the provisions of BS EN 12573-4 relating to the design and construction of flanged joints used when vertical thermoplastic vessels are constructed in sections and assembled on site.
- (2) A relevant PCBU must ensure that a tank is designed with a safety factor determined in accordance with clause 7 of BS EN 1778 of not less than 2.0.

7 Requirements relating to service life and materials

- (1) A relevant PCBU must ensure that a tank is designed for a service life of at least 25 years.
- (2) A relevant PCBU must ensure that a tank installed in a position where it is exposed to direct ultraviolet light is constructed of material stabilised against ultraviolet degradation with a minimum carbon black content of 2%.
- (3) A relevant PCBU must ensure that, if secondary containment is required for the tank with a capacity greater than 20 000 L, the secondary containment system is constructed independently of the tank and from material that is not the same as the material used to construct the tank.

8 Welding of tank during construction

- (1) A relevant PCBU must ensure that, during construction of a tank, a worker who welds the tank has received, or works under the direct supervision of a worker who has received, appropriate training.
- (2) A relevant PCBU must ensure that, during construction of a tank, a worker who welds the tank has welded test samples passed in accordance with relevant sections of DVS 2203 or an equivalent standard at intervals not exceeding 12 months, where the samples were of the same types of welds as those used in the construction of the tank.

9 Testing to be conducted by PCBU

- (1) A relevant PCBU must ensure that—
- (a) during construction of a tank, electronic spark testing is carried out of all welds to check for leaks; and
 - (b) if any leaks are detected, that the tank is repaired and re-rested until no further leaks are detected.
- (2) During construction of a tank, a relevant PCBU must ensure a hydrostatic test is conducted on the tank by completely filling the tank with water and applying a hydrostatic pressure at least equal to the specific gravity of the substance to be stored in the tank plus 10%.

- (3) The hydrostatic test required by subclause (2) must be of at least 8 hours' duration.
- (4) If any leaks are detected during the hydrostatic test, a relevant PCBU must ensure that the tank is repaired and further hydrostatic tests are conducted in accordance with subclauses (2) and (3) until no further leaks are detected.
- (5) A relevant PCBU must ensure that, in the case of a tank with a capacity greater than 20 000 L—
 - (a) at the conclusion of the hydrostatic test, the tank circumference is measured 200 mm above the base of the tank; and
 - (b) the measurement is recorded and retained by the PCBU for the design life of the tank.

10 Marking

A relevant PCBU must ensure that the tank is marked permanently and legibly with the following information, in addition to the matters specified in regulation 17.76(1)(b)(i) of the Regulations—

- (a) the design life of the tank;
- (b) the substances the tank is designed to contain;
- (c) the relevant reduction factor specified in BS EN 1778;
- (d) whether the tank has been designed and constructed for use in a position where it may be exposed to direct ultraviolet light.

11 Installation

- (1) If there is a risk that a tank, once installed, may be impacted by a moving vehicle, a PCBU with management or control of a tank must ensure a barrier is installed at a height above the ground and at a distance from the tank to prevent the vehicle from reaching the plan area of the tank.
- (2) Where any reasonably foreseeable impact is from a vehicle travelling at a speed not exceeding 20 km per hour, a Type G4 (W-beam) guardrail highway crash barrier that complies with AS/NZS 3845 meets the requirements of subclause (1).

12 Operation

- (1) A PCBU with management or control of a tank may not use the tank for the storage of—
 - (a) a class 1, 2, 3.1 or 4 substance; or
 - (b) sulphuric acid at a concentration greater than 80%; or
 - (c) nitric acid at a concentration greater than 10%; or
 - (d) hydrogen peroxide at a concentration greater than 20%; or
 - (e) sodium hypochlorite.
- (2) A PCBU with management or control of a tank must ensure, so far as is reasonably practicable, that two or more hazardous substances that are not compatible are not mixed in the tank.

- (3) Despite subclause (1)(e), a PCBU with management or control of a tank may use the tank for the storage of sodium hypochlorite at a concentration of 15% or less, if—
- (a) the barrel of the tank is annealed; and
 - (b) the maximum capacity of the tank is 7 000 L.

13 Maximum period of compliance certificate

For the purposes of regulation 17.92(1)(a)(i)(E) of the Regulations, the maximum period of validity of a compliance certificate issued under regulation 17.91 of the Regulations for a stationary container system that includes a tank is 5 years.

Made at Wellington on 13 November 2017.

Hon Iain Lees-Galloway
Minister for Workplace Relations and Safety

Date of notification in *Gazette*: 15 November 2017

This safe work instrument is administered by WorkSafe New Zealand.