

WORKSAFE

Mahi Haumarua Aotearoa

Exemption from provisions of Health and Safety at Work (Hazardous Substances) Regulations 2017

In accordance with section 220 of the Health and Safety at Work Act 2015 (the Act), I, Phil Parkes, Chief Executive at WorkSafe New Zealand, exempt Coca-Cola Amatil (N.Z.) Limited from compliance with regulation 17.56(3)(a)(i) of the Health and Safety at Work (Hazardous Substances) Regulations 2017 for the 7480 litre LPG tank and associated vapouriser (serial number: A0419120011369) at 41 Brightlings Road, Hillsborough, Christchurch ('the site').

I grant this exemption being satisfied that the extent of the exemption is not broader than is reasonably necessary to address the matters that gave rise to it, and that the exemption is not inconsistent with the purpose of the Act; and subject to the following conditions—

Coca-Cola Amatil (N.Z.) Limited must –

- (1) ensure that the vapouriser is 8 metres from any protected place when measured in a horizontal plane around the adjacent intervening wall along the western boundary of the site; and
- (2) maintain the intervening wall, along the western boundary of the site, adjacent to the vapouriser with a fire resistance rating of at least 240/240/240 minutes; and
- (3) hold a copy of this exemption at the site; and
- (4) provide a copy of this exemption to any compliance certifier engaged to issue a location compliance certificate.

This exemption takes effect on 13 October 2021 and expires 13 October 2026 unless it is replaced sooner or revoked. This exemption is given the reference *HS2104*.

Signed at Wellington this 7th day of October 2021



Phil Parkes
Chief Executive
WorkSafe New Zealand