

## Exemption Authorisation

In accordance with section 220 of the Health and Safety at Work Act 2015 (the Act), CHUBB New Zealand is exempted from compliance with regulations 15.13, 15.16 and 15.17 of the Health and Safety at Work (Hazardous Substances) Regulations 2017 for the requirements to have a design-verification compliance certificate, cylinder pre-commissioning compliance certificate and a cylinder import compliance certificate in respect to the single Manchester fire extinguisher cylinder with the serial number AA864729.

Regard has been given to (i) the prescribed requirements in regulation 15.18 of the HS Regulations; and (ii) being satisfied that the extent of the exemption is not broader than is reasonably necessary to address the matters that gave rise to the proposed exemption, and (iii) that the exemption is not inconsistent with the purposes of the Act.

The exemption is granted subject to the following conditions—

1. This exemption is limited to the single Manchester fire extinguisher cylinder with serial number AA864729.
2. The gas traffic for the single Manchester cylinder with serial number AA864729 is limited to FM200 ((Heptafluoropropane) & propellant gas (Nitrogen).
3. CHUBB New Zealand must in accordance with regulation 15.60, stamp the cylinder as follows:
  - a. Fire extinguisher cylinder AA864729 with the approval number LAB7736SP.
  - b. the station mark of the approved test station that marked the fire extinguisher cylinder with approval number LAB7736SP; and
  - c. The date the approval number LAB7736SP was marked on the cylinder.
4. CHUBB New Zealand must not stamp the approval number LAB7736SP on any other cylinder.

This exemption takes effect on **4<sup>th</sup> May 2022** and expires on **4<sup>th</sup> May 2027** unless it is sooner replaced or revoked.

Signed at Wellington this 21<sup>st</sup> day of April 2022.



Darren Handforth  
Head of High Hazards, Energy and Public Safety  
WorkSafe New Zealand